



SECTION A

1. All water mains which cross under sanitary sewer or storm sewer conduits shall be concrete encased and fully restrained.
2. No more than 2 joints of pipe under utility. Concrete encase 6" (MIN) around pipe & joint.
3. If water main is above sanitary sewer, but less than 18" separation, sanitary sewer must be encased 5' on each side of water main.

REVISION DATE: 9/7/2005	FIGURE NO. G-4	SHEET NO. 1 of 1
----------------------------	-------------------	---------------------

UTILITY CROSSING
STANDARD

ARAPAHOE COUNTY
Water and Wastewater Authority

13031 E Caley Ave, Centennial, Colorado 80111
Ph: (303) 790-4830 Fax: (303) 790-1718
© Copyright 2007 All Rights Reserved