



NOT TO SCALE

**NOTES:**

1. THIS DETAIL IS FOR BUTTERFLY VALVE INSTALLATIONS 20-INCHES IN DIAMETER OR SMALLER.
2. CARE SHALL BE TAKEN WHEN INSTALLING VALVES TO ASSURE PROPER SUPPORT OF THE VALVE. THE AUTHORITY MAY REQUIRE 3/4" CRUSHED ROCK TO BE INSTALLED UNDER THE VALVE TO PROVIDE PROPER SUPPORT.
3. VALVES SHALL NOT BE PLACED IN CONCRETE CROSS PANS.
4. OPERATING NUTS SHALL NOT BE SET CLOSER THAN THREE (3) FEET TO FINAL GRADE OR DEEPER THAN FIVE (5) FEET FROM FINAL GRADE. OPERATOR EXTENSIONS SHALL BE CONNECTED TO VALVE OPERATOR USING SET SCREW AND 12" BELOW FINAL GRADE.
5. BUTTERFLY VALVE AND OPERATOR SHALL BE POLYETHYLENE WRAPPED.



13031 E Caley Ave, Centennial, Colorado 80111  
 Ph: (303) 790-4830 Fax: (303) 790-1718  
 © Copyright 2007 All Rights Reserved

**BURIED BUTTERFLY VALVE**

REVISION DATE: 9/7/2005
FIGURE NO. W-14
SHEET NO. 1 of 1