



**NOTES:**

1. VALVE BOX SHALL BE SET AS TO BE 1/4" BELOW FINAL GRADE OF ASPHALT/CONCRETE PAVEMENT.
2. VALVE BOXES PLACED IN AREAS OTHER THAN PAVEMENT (I.E. DIRT OR LANDSCAPING) SHALL HAVE A 18"SQX6" THICK CONCRETE COLLAR SET FLUSH WITH FINAL GRADE. CONCRETE PAD TO BE PLACED USING PROPER FORMS; SET SQUARE AND FLUSH WITH GROUND SO AS TO LOOK PROFESSIONALLY CONSTRUCTED.
3. IF THE DISTANCE FROM FINAL GRADE TO THE OPERATING NUT IS GREATER THAN 6'-6" OPERATOR EXTENSIONS SHALL BE CONNECTED TO VALVE OPERATOR USING SET SCREW TO RAISE THE NUT TO WITHIN 12"-18" BELOW GRADE.
4. TYLER 6860 SERIES BOX WITH WIDE OVAL BASE, OR APPROVED EQUAL, REQUIRED ON ALL VALVES INCLUDING ALL CURB STOPS EXCEPT 3/4" RESIDENTIAL SERVICES. APPLICABLE 3/4" RESIDENTIAL SERVICE BOXES TO BE APPROVED BY ACWWA PRIOR TO INSTALLATION.
5. FOR FIRE HYDRANT VALVE, LID READS "FIRE".
6. DO NOT RUN TRACER WIRE UP VALVE BOXES.